

AN ACT

ENTITLED, An Act to revise the minimum fire safety standards for specialty resorts.

BE IT ENACTED BY THE LEGISLATURE OF THE STATE OF SOUTH DAKOTA:

Section 1. That § 34-18-22.1 be amended to read as follows:

34-18-22.1. Any specialty resort establishment with less than ten occupants shall meet the following minimum fire safety standards:

- (1) Any primary exit that leads to the exterior of the structure shall be capable of unlocking from the interior with single action hardware, free from obstruction, and clearly marked with illuminated exit signs. Any sleeping room with a direct exit to the exterior of the building is exempt from this requirement;
- (2) There shall be a smoke detector in each sleeping room. The owner or manager shall test any battery operated smoke detector at least twice a year;
- (3) Any sleeping room shall be equipped with an operable egress window. Any sleeping room with a direct exit to the exterior of the building is exempt from this requirement; and
- (4) Portable fire extinguishers with a minimum 2-A rating shall be made available on each floor and shall be inspected and tagged annually.

Section 2. That § 34-18-22.2 be amended to read as follows:

34-18-22.2. Any specialty resort establishment with ten or more occupants shall meet the following minimum fire safety standards:

- (1) Each floor where occupants are sleeping shall have access to at least two remote exits;
- (2) Any primary exit that leads to the exterior of the structure shall be capable of unlocking from the interior with single action hardware, free from obstruction, and clearly marked with illuminated exit signs. Any sleeping room with a direct exit to the exterior of the building is exempt from this requirement;

- (3) There shall be a smoke detector in each sleeping room. The owner or manager shall test any battery operated smoke detector at least twice a year;
- (4) Any sleeping room shall be equipped with an operable egress window. Any sleeping room with a direct exit to the exterior of the building is exempt from this requirement; and
- (5) Portable fire extinguishers with a minimum 2-A rating shall be made available on each floor and shall be inspected and tagged annually.

An Act to revise the minimum fire safety standards for specialty resorts.

I certify that the attached Act
originated in the

SENATE as Bill No. 30

Secretary of the Senate

President of the Senate

Attest:

Secretary of the Senate

Speaker of the House

Attest:

Chief Clerk

Senate Bill No. 30

File No. _____

Chapter No. _____

Received at this Executive Office
this ____ day of _____ ,

20__ at _____ M.

By _____
for the Governor

The attached Act is hereby
approved this _____ day of
_____, A.D., 20__

Governor

STATE OF SOUTH DAKOTA,
ss.
Office of the Secretary of State

Filed _____, 20__
at _____ o'clock __ M.

Secretary of State

By _____
Asst. Secretary of State